

PUBLIC NOTICE FOR COMMENT;
NPDES STORMWATER PERMIT APPLICATION

In accordance with DEP regulations at 25 Pa. Code § 92a.82(b), you are required to post near the entrance to your premises and, if the facility or discharge location is remote from these premises, at the entrance to the facility or at the discharge location. These postings shall remain for 30 days.

PA0245046, Industrial, SIC Code 9711, **Horsham Air Guard Station**, 1120 Fairchild Street, Horsham, PA 19044-5236. Facility Name: Horsham Air Guard Station. This proposed facility is located in Horsham Township, **Montgomery County**.

Description of Proposed Activity: The application is for a new NPDES permit for a new discharge of treated industrial waste.

The receiving stream(s), Unnamed Tributary to Park Creek (WWF, MF), is located in State Water Plan watershed 2-F and is classified for Migratory Fishes and Warm Water Fishes, aquatic life, water supply and recreation. The discharge is not expected to affect public water supplies.

The proposed effluent limits for Outfall 001 are based on a design flow of .288 MGD.—Limits.

Parameters	Mass Units (lbs/day)			Concentrations (mg/L)		
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum
Total Dissolved Solids	XXX	XXX	XXX	Report Avg Qrtly	Report	XXX

The proposed effluent limits for Outfall 001 are based on a design flow of .288 MGD.—Limits.

Parameters	Mass Units (lbs/day)			Concentrations (mg/L)		
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum
Flow (MGD)	Report	Report Wkly Avg	XXX	XXX	XXX	XXX
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0
Total Suspended Solids	XXX	XXX	XXX	Report	XXX	XXX

PFOA (ug/L)	XXX	XXX	XXX	Report	Report	XXX
PFOS (ug/L)	XXX	XXX	XXX	Report	Report	XXX
Total PFOA and PFOS (ug/L)	XXX	XXX	XXX	0.07	XXX	0.175

The proposed effluent limits for Outfall 003 are based on a design flow of 0 MGD.—Limits.

Parameters	Mass Units (lbs/day)		Concentrations (mg/L)			
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum
Total Suspended Solids	XXX	XXX	XXX	XXX	Report	XXX
Oil and Grease	XXX	XXX	XXX	XXX	Report	XXX

The proposed effluent limits for Outfall 003 are based on a design flow of 0 MGD.—Limits.

Parameters	Mass Units (lbs/day)		Concentrations (mg/L)			
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum
PFOA (ug/L)	XXX	XXX	XXX	Report	Report	XXX
PFOS (ug/L)	XXX	XXX	XXX	Report	Report	XXX
Total PFOA and PFOS (ug/L)	XXX	XXX	XXX	0.07	XXX	0.175

The proposed effluent limits for Outfall 201 are based on a design flow of 0.0 MGD.—Limits.

Parameters	Mass Units (lbs/day)		Concentrations (mg/L)			
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum
PFOA (ug/L)						
Internal Monitoring Point	XXX	XXX	XXX	Report	Report	XXX
PFOS (ug/L)						
Internal Monitoring Point	XXX	XXX	XXX	Report	Report	XXX
Total PFOA and PFOS (ug/L)						
Internal Monitoring Point	XXX	XXX	XXX	Report	Report	XXX

In addition, the permit contains the following major special conditions:

- Permit may be revoked or modified to conform with applicable ELG(s)
- Development of a treatment facility O&M plan
- Obtain a WQM permit
- Requirements applicable to Stormwater Outfalls
- Requirement to divert flows from IMP201 to the future treatment plant

You may make an appointment to review the DEP files on this case by calling the File Review Coordinator at 484-250-5910.

The EPA Waiver is in effect.